



China

Attestation of Conformity

No. N8AUK 112096 0005 Rev. 00

Holder of Attestation: Hunan Harnitek Technology Co., Ltd.

Room 1504, Bldg 13, No. 1006, Renmin Road, Lusong District
412000 Zhuzhou City, Hunan Province
PEOPLE'S REPUBLIC OF CHINA

Product:

Heat pumps

(DC Inverter Air to Water Heat Pump Unit)

This Attestation of Conformity is issued on a voluntary basis according to the Electrical Equipment (Safety) Regulations 2016 relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the regulation and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment.

For details see: www.tuvsud.com/ps-cert

Test report no.:

64111210157002

Date, 2023-02-28

(Sam Yang)

Page 1 of 2

This Attestation does not replace the regulatory UK Declaration of Conformity (DoC) and does not allow for UKCA marking. After preparation of the necessary technical documentation and establishing compliance to requirements of all applicable regulations, the manufacturer may sign a DoC and apply the UKCA marking. The DoC is issued under the sole responsibility of the manufacturer.

**UK
CA**

TÜV®



China

Attestation of Conformity

No. N8AUK 112096 0005 Rev. 00

Model(s): Outdoor unit/Indoor unit
 YHPK-06V1TBA/YHPK-06V1TBA
 YHPK-06V1TBA/YHPK-06V1TBA-250L
 YHPK-09V1TBA/YHPK-09V1TBA
 YHPK-09V1TBA/YHPK-09V1TBA-250L
 YHPK-12V1TBA/YHPK-12V1TBA
 YHPK-12V1TBA/YHPK-12V1TBA-250L

Brand: HARNITEK

HARNITEK

Parameters:

Rated Voltage:	220-240V
Rated Frequency:	50Hz
Rated input:	Cooling/Heating
YHPK-06V1TBA/ YHPK-06V1TBA:	1691W/5500W;
YHPK-06V1TBA/ YHPK-06V1TBA-250L:	1691W/5500W;
YHPK-09V1TBA/ YHPK-09V1TBA:	2410W/6200W;
YHPK-09V1TBA/ YHPK-09V1TBA-250L:	2410W/6200W;
YHPK-12V1TBA/ YHPK-12V1TBA:	2610W/6900W;
YHPK-12V1TBA/ YHPK-12V1TBA-250L:	2610W/6900W;
Supplementary heaters power input:	3000W
Protection Class:	Class I
Degree of Protection:	IPX4 for outdoor unit, IPX0 for indoor unit.
Refrigerant:	R32

Tested according to: EN 60335-1:2012/A15:2021
 EN 60335-2-40:2003/A13:2012
 EN 62233:2008

Page 2 of 2

This Attestation does not replace the regulatory UK Declaration of Conformity (DoC) and does not allow for UKCA marking. After preparation of the necessary technical documentation and establishing compliance to requirements of all applicable regulations, the manufacturer may sign a DoC and apply the UKCA marking. The DoC is issued under the sole responsibility of the manufacturer.

UK CA

TÜV®